






ENDURALUX T 1250





ENT-1250-ML-CW	ENT-1250-ML-CW-EP	ENT-1250-ML-CW-DA	ENT-1250-ML-CW-DA-EP
ENT-1250-LO-CW	ENT-1250-LO-CW-EP	ENT-1250-LO-CW-DA	ENT-1250-LO-CW-DA-EP
ENT-1250-HE-CW	ENT-1250-HE-CW-EP	ENT-1250-HE-CW-DA	ENT-1250-HE-CW-DA-EP
ENT-1250-NM-CW	ENT-1250-NM-CW-EP	ENT-1250-NM-CW-DA	ENT-1250-NM-CW-DA-EP
ENT-1250-HO-CW	ENT-1250-HO-CW-EP	ENT-1250-HO-CW-DA	ENT-1250-HO-CW-DA-EP
ENT-1250-MX-CW	ENT-1250-MX-CW-EP	ENT-1250-MX-CW-DA	ENT-1250-MX-CW-DA-EP
ENT-1250-ML-WW	ENT-1250-ML-WW-EP	ENT-1250-ML-WW-DA	ENT-1250-ML-WW-DA-EP
ENT-1250-LO-WW	ENT-1250-LO-WW-EP	ENT-1250-LO-WW-DA	ENT-1250-LO-WW-DA-EP
ENT-1250-HE-WW	ENT-1250-HE-WW-EP	ENT-1250-HE-WW-DA	ENT-1250-HE-WW-DA-EP
ENT-1250-NM-WW	ENT-1250-NM-WW-EP	ENT-1250-NM-WW-DA	ENT-1250-NM-WW-DA-EP
ENT-1250-HO-WW	ENT-1250-HO-WW-EP	ENT-1250-HO-WW-DA	ENT-1250-HO-WW-DA-EP
ENT-1250-MX-WW	ENT-1250-MX-WW-EP	ENT-1250-MX-WW-DA	ENT-1250-MX-WW-DA-EP




1) Unscrew and remove lens, setting aside M6 x 16 screws and washers




2) Unscrew and remove gear tray, setting aside M6 x 12 screws




3) Drill fixing holes into ceiling and screw into place. Use x4 M6 bonded washers supplied to ensure IP seal.




4) Wire power cable into terminal block. Max Ø1.8mm gauge



5) Connect flying lead from body into gear tray.



7) Place Gear tray into body and screw into place with M6 x 12 screws



8) Screw Lens to Body with M6 x 16 screws and washers